

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10779

1. OWNER R J Amdell ADDRESS AT WELL LOCATION 2595 7th St. Silver Springs, NV. 89429  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec 17 T. 20 N/S R. 25 E Lyon County  
 PERMIT NO. 17-342-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	63	
Clay		63	86	
Sand silt		86	142	
Clay		142	186	
Gravels		186	220	

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 105 1/8 Inches To 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65 1/8</u>	<u>13.00</u>	<u>3 1/16</u>	<u>4</u>	<u>20</u>
<u>65 1/8</u>	<u>300</u>	<u>5 1/4</u>	<u>20</u>	<u>220</u>

Perforations:  
 Type perforation Full Casing  
 Size perforation 1 1/4 x 6 Long Slows  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 200 feet

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-22  
 Date completed 3-23

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>Produced about 50 GPM</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Teach Drilling Inc  
 Address PO Box 599 Silver Springs NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 31841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1977  
 Signed Matthew Teach  
 By driller performing actual drilling on site or contractor  
 Date 3-23-00