

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40788

1. OWNER Guard LTD. ADDRESS AT WELL LOCATION 1540 Rail Road Silver Spring
 MAILING ADDRESS 3130 Villa Marbella Circle, Reno, NV 89509 NV. 89429
 2. LOCATION SW 1/4 NE 1/4 Sec 6 T 17 N/S R 25 E Lyon County
 PERMIT NO. 17-083-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other none

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY ORT</u>		<u>0</u>	<u>35'</u>	<u>35'</u>
<u>COURSE SAND</u>		<u>35</u>	<u>83'</u>	<u>48'</u>
<u>CLAY + GRAVEL</u>		<u>83</u>	<u>163'</u>	<u>80'</u>
<u>GRAVEL & SAND</u>	<input checked="" type="checkbox"/>	<u>163</u>	<u>190'</u>	<u>27</u>

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 191 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 190 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>188</u>	<u>71'</u>	<u>20</u>
<u>6 5/8</u>	<u>AVE SCA 40</u>		<u>20</u>	<u>190'</u>

Perforations:
 Type perforation SAWED
 Size perforation 6 7/8" 4" FOUR ROWS
 From 170' feet to 190' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 190 feet

9. WATER LEVEL
 Static water level 48' - 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

Date started 4/8/00, 19____
 Date completed 4/9/00, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>35</u>	<u>60' M</u>	<u>FOR 3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc. Contractor
 Address P.O. Box 589 Contractor
Silver Springs NV. 89429
 Nevada contractor's license number issued by the State Contractor's Board: 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1740
 Signed Nathaniel S. Deak Sr.
 By driller performing actual drilling on site or contractor
 Date 5/9/00

RECEIVED
 DIVISION OF WATER RESOURCES
 JUNE 16 2000