

OFFICE USE ONLY
 Log No. 79580
 Permit No. 107
 Basin
 NOTICE OF INTENT NO. 40786

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Guard LTD ADDRESS AT WELL LOCATION 5400 Rail Road St. Silver Springs NV 89429
 MAILING ADDRESS 3130 Villa Marbella Circle Reno NV 89509
 2. LOCATION SW 1/4 NE 1/4 Sec. 6 T. 17 N/S R. 25 E Lyon County
 PERMIT NO. 17-083-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY DIRT</u>		<u>0</u>	<u>30'</u>	<u>30'</u>
<u>COURSE SAND</u>		<u>30'</u>	<u>76'</u>	<u>46'</u>
<u>CLAY & GRAVEL</u>		<u>76'</u>	<u>158'</u>	<u>82'</u>
<u>GRAVEL & SAND</u>	<u>✓</u>	<u>158'</u>	<u>180'</u>	<u>22'</u>

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 181 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 9/16 Inches +1 Feet 180 Feet
 To Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>1.88</u>	<u>+1</u>	<u>20'</u>
<u>6 5/8</u>	<u>Puesch 40</u>	<u>40</u>	<u>20'</u>	<u>180'</u>

Perforations:
 Type perforation Sawed
 Size perforation 1/8 x 4" 47# Rows
 From feet to feet
 From 100' feet to 180' feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 180' feet

9. WATER LEVEL
 Static water level 43' feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Cold °F Quality Clear

Date started 4/9/00 19...
 Date completed 4/10/00 19...

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>OPM FOR 3 HRS.</u>	<u> </u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling, Inc Contractor
 Address Po Box 599 Contractor
Silver Springs NV, 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Nathaniel S. Leach Sr
 By driller performing actual drilling on site or contractor
 Date 5/9/00