

OFFICE USE ONLY
 Log No. 79597
 Permit No. 101
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43300

1. OWNER Don Travis ADDRESS AT WELL LOCATION 1771 Lammel Pl Fallon
 MAILING ADDRESS PO Box 1662 Nv. 89406
Fallon, NV 89407

2. LOCATION SE 1/4 NW 1/4 Sec. 24 T 19N N/S R 28E E Churchill County
 PERMIT NO. 8-263-17 Parcel No. 8-263-17 Subdivision Name Churchill
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	20	20
Brown Sand		20	30	10
Gray Clay		30	35	5
Brown Sand		35	50	15
Black Silt		50	65	15
Gray Sand		65	80	15
Brown Sand		80	90	10
Brown clay		90	95	5
Brown Sand	XX	95	108	13

8. WELL CONSTRUCTION
 Depth Drilled 108 Feet Depth Cased 108 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 108 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6	3.92	.258	10	108

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8

From <u>100</u>	feet to	<u>105</u>	feet
From	feet to		feet
From	feet to		feet
From	feet to		feet
From	feet to		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 108 feet

9. WATER LEVEL
 Static water level 9' 7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor
Fallon Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
 Signed Wayne Parsons
 By driller performing actual drilling on-site or contractor
 Date 01/14/20

Date started 12/27/1999, 19
 Date completed 12/27/1999, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>		<u>1 hr</u>	