WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79636
Permit No.
Basin 102

NOTICE OF INTENT NO. 44[illegible]09

1. OWNER Ted Wilson
MAILING ADDRESS P.O.Box 527
Silver Springs, NV 89429

ADDRESS AT WELL LOCATION 2705 Hwy 50 East,
Silver Springs

2. LOCATION NW 1/4 SE 1/4 Sec. 17 T 18 N/S R 25 E Lyon County
PERMIT NO. (Issued by Water Resources) | Parcel No. 1526304 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	30	30
Gray Clay		30	50	20
Gray sand		50	70	20
Brown Clay		70	87	17
Brown Sand		87	92	5
Gravel	XX	92	120	28

Date started 03/19/2000, 19__
Date completed 03/19/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		1HR

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	14.96	.188	0	10
8 pvc	7.17	.258	10	120

Perforations:
Type perforation saw cut
Size perforation 1/8
From 105 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 03/23/2000

USE ADDITIONAL SHEETS IF NECESSARY