WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79662
Permit No.
Basin 89

NOTICE OF INTENT 38049

1. OWNER Doug Deacy
MAILING ADDRESS 35 Bear St.
Carson City, NV 89704

ADDRESS AT WELL LOCATION 35 Bear St.

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
PERMIT NO. WaCo#6569 Issued by Water Resources
50-387-09 Parcel No.
Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [ ] Deepen
- [x] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [ ] Rotary
- [ ] RVC
- [ ] Air
- [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
On this date we abandoned the 6 5/8" domestic well by perforating the casing from 50' to surface at four around and 1' intervals. We pumped approximately 1 cu. yard neat cement from bottom to top using tremie pipe and pressure grout pump. This brought neat cement level up to surface, but slowly lowered to about 8'. We then topped off the remaing 8' with 6 sack sand grout.				

Date started 3/23/2000, 19__
Date completed 3/31/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	63

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 50 feet to Surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [x] Pumped [ ] Poured

Seal Type:
- [x] Neat Cement
- [ ] Cement Grout
- [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL

Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 3/31/2000

USE ADDITIONAL SHEETS IF NECESSARY