

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 79677
 Permit No. _____
 Basin 85

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43796

1. OWNER Granite Construction ADDRESS AT WELL LOCATION application # 458
 MAILING ADDRESS P.O. Box 2087
Sparks, NV 89432

2. LOCATION NW 1/4 NE 1/4 Sec. 9 T 20N N/S R. 20E E Washoe County
 PERMIT NO. waiver W-517 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____ Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fractured rock		0	90	
hard rock		90	220	130
fractured rock		220	300	80
hard rock		300	386	86
fractured rock	x	386	426	40
solid rock		426	560	134
fractured rock		560	620	60
decomposed rock		620	900	280

ABANDONMENT

tripped in trimmie
 pipeto 390 ft.-pipe
 would not go any further
 due to cave-in from the
 top. Pumped grout from
 390ft. to 87ft. Poured
 from 87ft. to 10ft.
 below surface. Took 7
 cy. of 7 sack grout

8. WELL CONSTRUCTION
 Depth Drilled 900 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>9-7/8</u> Inches	<u>0</u> Feet	<u>10</u> Feet
<u>6-1/8</u> Inches	<u>10</u> Feet	<u>900</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation n/a
 Size perforation n/a

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 400 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 344 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 4/5/00

Date started 2/24/00, 19____
 Date completed 3/21/00, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>17</u>		<u>5 hrs</u>