WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 19683
Permit No.
Basin 101

NOTICE OF INTENT NO. 43805

1. OWNER Budge Brown
MAILING ADDRESS 397 Foothill Rd.
Gardnerville, NV. 89410

ADDRESS AT WELL LOCATION 12241 Pioneer Way,
Fallon

2. LOCATION NW 1/4 SW 1/4 Sec. 29 T 19 N/S R 27 E Churchill County
PERMIT NO. | Issued by Water Resources | Parcel No. 7-091-20 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

6. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ABANDONMENT | | | | |
| This well was abandon by | | | | |
| perforating casing from | | | | |
| 0-100 ft. and pumped | | | | |
| with 2.5 yds. of neat | | | | |
| cement from 160 ft. to | | | | |
| surface. | | 0 | 160 | 160 |

RECEIVED
00 MAY -8 PM 12:51
STATE ENGINEER'S OFFICE

Date started 4/3 2000
Date completed 4/3 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | | | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 160
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed
By driller performing actual drilling on-site or contractor

Date 5/5/00