

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 79690  
 Permit No. 42  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31559

1. OWNER **TEHAMA HOLDING**  
 MAILING ADDRESS **100 W. GROVE SUITE 125**  
**RENO, NV 89509**

ADDRESS AT WELL LOCATION **SW CORNER OF SCAUP & 2ND ST.**

2. LOCATION **SW 1/4 SW 1/4 Sec. 3 T 36N**  
 PERMIT NO. **020-015-001**  
Issued by Water Resources Parcel No.

**N/S R 58E E ELKO** County  
**HUMBOLDT ACRES #3**  
Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	2	2
SAND & GRAVEL		2	6	4
SILTSTONE		6	100	94
GRAY CLAY	135	100	160	60

8. WELL CONSTRUCTION  
 Depth Drilled **160** Feet Depth Cased **160** Feet  
 HOLE DIAMETER (BIT SIZE)  
**10 5/8** Inches From **0** Feet To **160** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	160

Perforations:  
 Type perforation **MILLSLOT**  
 Size perforation **3/16 X 3**  
 From **140** feet to **160** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **50** feet to **160** feet

9. WATER LEVEL  
 Static water level **101** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **C** °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** Contractor  
 Address **P.O. BOX 850** Contractor  
**ELKO, NV 89803**  
 Nevada contractor's license number issued by the State Contractor's Board **020582**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**  
 Signed *[Signature]*  
 by driller performing actual drilling on-site or contractor  
 Date **03/21/2000**

Date started **03/17/2000**, 19\_\_\_\_  
 Date completed **03/17/2000**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<b>20</b>		<b>3</b>	