WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79691
Permit No.
Basin 42

NOTICE OF INTENT NO. 37558

1. OWNER TEHAMA HOLDING
MAILING ADDRESS 100 W. GROVE SUITE 125
RENO, NV 89509

ADDRESS AT WELL LOCATION NO. SIDE OF BALDPAT
BETWEEN 4TH & 5TH ST.

2. LOCATION NE 1/4 SE 1/4 Sec. 3 T 36N N/S R 58E E ELKO County
PERMIT NO. Issued by Water Resources
019-009-006 Parcel No.
HUMBOLDT ACRES #2 Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SANDY GRAVEL		2	8	6
BROWN SILTSTONE		8	90	82
GRAY CLAY	120	90	260	170
SANDSTONE	280	260	300	40

Date started 03/16/2000 , 19__
Date completed 03/16/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
65		3

8. **WELL CONSTRUCTION**
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	300

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. **WATER LEVEL**
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC Contractor
Address P.O.BOX 850 Contractor
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] By driller performing actual drilling on-site or contractor
Date 03/21/2000

USE ADDITIONAL SHEETS IF NECESSARY