WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79703
Permit No.
Basin 76

NOTICE OF INTENT NO. 42758

1. OWNER DAN LAMB
MAILING ADDRESS 1305 MESA
FERNLEY, NV 89419

ADDRESS AT WELL LOCATION 1305 MESA

2. LOCATION NE 1/4 SW 1/4 Sec. 10 T 20 N/S R 24 E LYON County
PERMIT NO. Issued by Water Resources
Parcel No. 21-051-40
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR SAND		0	6	6
BR CLAY		6	15	9
BR SAND		15	20	5
BR CLAY		20	30	10
MC GRAVELS		30	90	60
BR CLAY		90	94	4
MC GRAVELS	X	94	120	26
BR CLAY		120	160	40

RECEIVED 00 MAR 31 AM 11:26 STATE ENGINEER'S OFFICE

Date started 10/12/1999 , 19__
Date completed 2/28/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	120

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 115 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO DRILLING CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 3/28/2000

USE ADDITIONAL SHEETS IF NECESSARY