WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79705
Permit No.
Basin 101

NOTICE OF INTENT NO. 43632

1. OWNER LAHONTAN HOMES
MAILING ADDRESS 4700 RENO HWY
FALLON, NV 89406, NV 89406

ADDRESS AT WELL LOCATION 2345 LUCAS ROAD

2. LOCATION NE 1/4 SE 1/4 Sec. 13 T 19 N/S R 27 E CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY CLAY		0	15	15
GREY SAND		15	25	10
GREY CLAY		25	30	5
GREY SAND		30	60	30
RED SILT		60	85	25
BROWN CLAY		85	90	5
BROWN SAND/GRAVEL	X	90	102	12

Date started 2/21/2000, 19__
Date completed 2/29/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 102 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 5/8 Inches		0 Feet	102 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	102

Perforations:
Type perforation MACHINE PERF
Size perforation .080
From 96 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 per telcon
Placement Method: [X] Pumped w/ Welsco
[ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 9'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed [signature] By driller performing actual drilling on-site or contractor
Date 3/22/2000

USE ADDITIONAL SHEETS IF NECESSARY