

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 211739

1. OWNER CAS UEGAS PAVING ADDRESS AT WELL LOCATION ENCL OFF.
MAILING ADDRESS 4420 S. DECATUR SUNSET BLVD & CAS UEGAS WASH
CAS UEGAS, NV 89103
2. LOCATION SW 1/4 S 1/2 Sec. 30 T. 21 N/S R. 65 E CLARK County
PERMIT NO. DW 1112 Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other well points
4. PROPOSED USE dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~285-342~~ LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| 1. <u>Silty sand w/ gravel (Sp) dense, light brown</u> | | 4' | 0' | 3' |
| 2. <u>Clay sand w/ gravel (Sp) medium dense brown</u> | | 4' | 3' | 13' |
| 3. <u>poorly graded sand w/ silt & gravel (Sp-Sm) Very coarse clays</u> | | 4' | 13' | 20' |

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet
HOLE DIAMETER (BIT SIZE)
From 2" Inches To 20" Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|---------------------------|-------------|-----------|
| <u>2"</u> | <u>PVC</u> | <u>Sch 40 well points</u> | <u>0</u> | <u>20</u> |

Perforations:
Type perforation Factory Perf well points
Size perforation 070
From 20 feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality Good

Date started 3-16-00
Date completed 3-16-00

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|----------------|-------------------------------|---------------|
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>Appx 40</u> | <u>5</u> | <u>20 min</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hill Energy & Dewatering
Address 905 E. 3rd St. Corona CA, 91719
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed Steve Duke
By driller performing actual drilling on site or contractor
Date 3-16-00