

OFFICE USE ONLY
 Log No. 79742
 Permit No. DW 112
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 6/17/39

1. OWNER CAS VEGAS PAVING ADDRESS AT WELL LOCATION ENCL O.F.E.
 MAILING ADDRESS 4420 S. DECATUR CONSET REL & CAS VEGAS WASH
CAS VEGAS NV 89103
 2. LOCATION SW 1/4 S 1/2 sec. 30 T. 21 N/S R. 65 E CLARK County
 PERMIT NO. DW 112 Parcel No. 160-30-003 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other well points

4. PROPOSED USE dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1. S. lty sand w/ gravel (sm) dense, light brown</u>		<u>4'</u>	<u>0'</u>	<u>3'</u>
<u>2. clay sand w/ gravel (sc) medium coarse brown</u>		<u>4'</u>	<u>3'</u>	<u>13'</u>
<u>3. poorly graded sand w/ silt & gravel (sp-sm) very coarse clays</u>		<u>4'</u>	<u>13'</u>	<u>20'</u>

8. WELL CONSTRUCTION
 Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)
 From 2" Inches To 20" Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0-20</u>	

Perforations:
 Type perforation Factory Perf well points
 Size perforation 070
 From 20' feet to 18' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 3-16-00
 Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>Appx 40</u>	<u>5</u>	<u>20 min</u>

9. WATER LEVEL
 Static water level 4' feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Foot Hill Eng & Demolition Contractor
 Address 905 E. 3rd St. Contractor
CORONA CA, 91719
 Nevada contractor's license number 0035906
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the M2119
 Division of Water Resources, the on-site driller.
 Signed Jim J. [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-16-00