

OFFICE USE ONLY  
 Log No. 79747  
 Permit No. DW-1112  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 411739

1. OWNER CAS VEGAS PAUING ADDRESS AT WELL LOCATION ENCL OF E.  
 MAILING ADDRESS 4420 S. DECATUR SUNSET RD & CAS VEGAS WASH  
CAS VEGAS, NV 89103  
 2. LOCATION SW 1/4 S 30 T 21 N/S R 65 E CLARK County  
 PERMIT NO. DW 1112 Issued by Water Resources Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other well points  
 4. PROPOSED USE dewater  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. <u>S. lly sand w/ gravel (sp) dense, light brown</u>		4'	0'	3'
2. <u>CLAY sand w/ gravel (Si) medium dense brown</u>		4'	3'	13'
3. <u>poorly graded sand w/silt &amp; gravel (sp. sm) very coarse clus</u>		4'	13'	20'

8. WELL CONSTRUCTION  
 Depth Drilled 20' Feet Depth Cased 17'-20' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2" Inches To 20" Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation Fracking Perfor well points  
 Size perforation 0.70  
 From 20 feet to 18' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FOOT Hill Eng & Demolition  
 Address 905 E. 3rd St. Corona CA, 91719  
 Nevada contractor's license number issued by the State Contractor's Board 0035906  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller m2119  
 Signed Sam J. Davis  
 By driller performing actual drilling on site or contractor  
 Date 3-16-00

Date started 3-16-00  
 Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>APPRX 40</u>	<u>0</u>	<u>20 min</u>