

OFFICE USE ONLY
Log No. 79749
Permit No. DW 712
Basin _____
NOTICE OF INTENT NO. 41739

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION END OF E. SUNSET BLVD LAS VEGAS WASH
MAILING ADDRESS 4420 S. DECATUR LAS VEGAS, NV 89103
2. LOCATION SW 1/4 S 1/2 Sec. 30 T. 21 N/S R. 65 E CLARK County
PERMIT NO. DW 712 Parcel No. 162-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other well points
4. PROPOSED USE dewater
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. <u>Silty sand w/ gravel (sp) dense, light brown</u>		4'	0'	3'
2. <u>Clay sand w/ gravel (Si) medium dense brown</u>		4'	3'	13'
3. <u>poorly graded sand w/ silt & gravel (sp sm) very large cobbles</u>		4'	13'	20'

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet
HOLE DIAMETER (BIT SIZE)
From 2" To 20"
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0-20</u>	

Perforations:
Type perforation Factory Perf well points
Size perforation 070
From 20 feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
Depth of Seal _____
Placement Method: Pumped Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality Good

Date started 3-16-00
Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>Appx 40</u>	<u>5</u>	<u>20 min</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hill Eng & Demolition Contractor
Address 905 E. 3rd St. Corona CA, 91719 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed Jim J. [Signature]
By driller performing actual drilling on site or contractor
Date 3-16-00