

OFFICE USE ONLY
Log No. 79753
Permit No. DW 111217
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 611739

1. OWNER LAS VEGAS DAWING ADDRESS AT WELL LOCATION ENCLOSURE
MAILING ADDRESS 4420 S. DECATUR SUNSET BLVD LAS VEGAS WASH
LAS VEGAS, NV 89103

2. LOCATION SW 1/4 S 1/2 sec. 30 T. 21 N/S R 65 E CLARK County
PERMIT NO. DW 1112 160-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other well points Municipal/Industrial Irrigation Test Monitor Stock

4. PROPOSED USE dewater

5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1. S. ly sand w/ gravel (sm) dense, light brown</u>		<u>4'</u>	<u>0'</u>	<u>3'</u>
<u>2. clay sand w/ gravel (Si) medium dense brown</u>		<u>4'</u>	<u>3'</u>	<u>13'</u>
<u>3. poorly graded sand w/ silt & gravel (sp sm) very large cobbles</u>		<u>4'</u>	<u>13'</u>	<u>20'</u>

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)
From 2" Inches To 20" Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0</u>	<u>20</u>

Perforations:
Type perforation Factory Perf well points
Size perforation 070
From 20 feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 3-16-00
Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>Appx 40</u>	<u>5</u>	<u>20 min</u>

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Foot Hill Eng & Demolition Contractor
Address 905 E. 3rd St. Contractor
CORONA CA, 91719

Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119

Signed Jim J. [Signature]
By driller performing actual drilling on site or contractor
Date 3-16-00