

OFFICE USE ONLY
Log No. 29757
Permit No. DW 11127
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 011739

1. OWNER CAS UEGAS PAVING ADDRESS AT WELL LOCATION ENCL OFFE
MAILING ADDRESS 4420 S. DECAHU SUNSET REL & CAS UEGAS WASH
CAS UEGAS, NV 89103
2. LOCATION SW 1/4 S 1/4 Sec. 30 T. 21 N/S R 65 E CLARK County
PERMIT NO. DW 1112 Issued by Water Resources | 160-30-003 Parcel No. | _____ Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other well points

4. PROPOSED USE dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~160-30-003~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>285-342</u> 1. S. lgy sand w/ gravel (sm) dense, light brown		0'	3'	3'
2. clay sand w/ gravel (Si) medium dense brown		3'	13'	10'
3. poorly graded sand w/ silt & gravel (sp sm) very coarse clays		13'	20'	7'

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)
From 2" Inches To 20" Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0-20</u>	

Perforations:
Type perforation Factory Pref well points
Size perforation 070
From 20 feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality Good

Date started 3-14 2000
Date completed 3-14 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>Appx 40</u>	<u>5</u>	<u>20 min</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Foot Hill Eng & Demolition Contractor
Address 905 E. 3rd St. Contractor
CORONA CA, 91719
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed Jim J. [Signature]
By driller performing actual drilling on site or contractor
Date 3-16-00