

OFFICE USE ONLY
Log No. 79765
Permit No. DW 1112
Basin
41739

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION ENCL OF E.
MAILING ADDRESS 4420 S. DECATUR SUNSET REL & LAS VEGAS WASH
LAS VEGAS, NV 89103
2. LOCATION SW 1/4 S 1/2 sec. 30 T. 21 N/S R. 65 E CLARK County
PERMIT NO. DW 1112 Parcel No. 166-30-063 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other well points
4. PROPOSED USE dewater
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. Silty sand w/ gravel (Sp) dense, light brown	4'	0'	3'	3'
2. Clay sand w/ gravel (Si) medium dense brown	4'	3'	13'	10'
3. poorly graded sand w/ silt & gravel (Sp Sm) Very large clasts	4'	13'	20'	7'

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet
HOLE DIAMETER (BIT SIZE)
From 2" Inches To 20" Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40 well points	0-20	

Perforations:
Type perforation Factory Pref well points
Size perforation 070
From 20 feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FOOT HILL ENG & DEMONSTRATIONS Contractor
Address 905 E. 3rd St. Contractor
CORONA CA, 91719
Nevada contractor's license number issued by the State Contractor's Board. 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed Sam J. [Signature]
By driller performing actual drilling on site or contractor
Date 3-16-00

Date started 3-16-00
Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>Appx 40</u>	<u>0</u>	<u>20 min</u>