

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS DRAINAGE ADDRESS AT WELL LOCATION ENCLOSURE  
 MAILING ADDRESS 4420 S. DECAUR SUNSET BLVD LAS VEGAS WASH  
LAS VEGAS, NV 89103  
 2. LOCATION SW 1/4 S 1/2 sec. 30 T. 21 N/S R. 65 E 3 CLARK County  
 PERMIT NO. DW 1112 Parcel No. 166-30-003 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other well points

4. PROPOSED USE dewater  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other well points

6. ~~285-342~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. <u>Silty sand w/ gravel (sm) dense, light brown</u>	4'	0'	3'	3'
2. <u>Clay sand w/ gravel (Si) medium dense brown</u>	4'	3'	13'	10'
3. <u>poorly graded sand w/ silt &amp; gravel (sp sm) very coarse clays</u>	4'	13'	20'	7'

8. WELL CONSTRUCTION  
 Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)  
 From 2" Inches To 20" Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40 well points</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation Factory Perf well points  
 Size perforation 070  
 From 20 feet to 18' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-16-00  
 Date completed 3-16-00

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>Appx 40</u>	<u>5</u>	<u>20 min</u>

9. WATER LEVEL  
 Static water level 4' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Foot Hill Eng & Drilling  
 Address 905 E. 3rd St. Corona CA, 91719  
 Nevada contractor's license number 0035906  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119  
 Signed Jim J. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-16-00