

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER CAS VEGAS PAVING CORP. ADDRESS AT WELL LOCATION ENCL OF E. SUNSET RD & CAS VEGAS WASH
 MAILING ADDRESS 4420 S. DECATUR CAS VEGAS NV 89103

2. LOCATION SW 1/4 Sec. 30 T. 21 N/S R. 63 E CLARK County
 PERMIT NO. DW 9112 Issued by Water Resources Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other well points

4. dewater PROPOSED USE Dewatering
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other well points

6. ~~150~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
1. Silty sand (sm) <u>DOUBTS, medium dense, BEAN</u>	4'	0	5	5'
2. <u>poorly graded</u> gravel w/ sand (gp) <u>medium dense gray to black</u>	4'	5	12	7'
3. Silty sand (sm) <u>Fine Gravel, medium dense, gray</u>	4'	12	16	4'
<u>poorly graded</u> gravel with silt & sand (gp-gm)	4'	16	20	4'

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 17-20 Feet

HOLE DIAMETER (BIT SIZE)
 From 2 Inches To 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>AW</u>	<u>3/4</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation Factory perf well points
 Size perforation 100

From 80 feet to 18 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 4 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality Good

Date started 3-13 1900
 Date completed 3-14 1900

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pump</u>	<u>APX 65</u>	<u>0</u>	<u>20 min</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Foot Hill Eng & Dewatering Contractor
 Address 905 E. THIRD ST. COVINGTON, LA 70719 Contractor
 Nevada contractor's license number issued by the State Contractor's Board. 0035906
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M 2119
 Signed Jim J. Smith
 By driller performing actual drilling on site or contractor
 Date 3-13-00