

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER CAS VEGAS PAVING CORP. ADDRESS AT WELL LOCATION ENCL OF E. SUNSET RD & CAS VEGAS WASH  
 MAILING ADDRESS 4410 S. DECADE CAS VEGAS, NV 89103  
 2. LOCATION SW 1/4 Sec 30 T. 21 N/S R. 63 E CLARK County  
 PERMIT NO. DW 1112 Issued by Water Resources | 160-30-003 Parcel No. | \_\_\_\_\_ Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other well points  
 4. dewater PROPOSED USE Dewatering  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other well point

6. ~~150~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1. Silty Sand (sm) 25-285</u> <u>Downs medium dense, brown</u>	<u>4'</u>	<u>0</u>	<u>5</u>	<u>5'</u>
<u>2. poorly Graded sand w/ sand (gp)</u> <u>Medium dense gray to black</u>	<u>4'</u>	<u>5</u>	<u>12'</u>	<u>7'</u>
<u>3. Silty Sand (sm)</u> <u>Fine Gravel, medium dense, gray</u>	<u>4'</u>	<u>12</u>	<u>16'</u>	<u>4'</u>
<u>4. poorly Graded sand with silt &amp; gravel (gp-gm)</u>	<u>4'</u>	<u>16'</u>	<u>20'</u>	<u>4'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 20' Feet Depth Cased 12'-20' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2' Inches To 20' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PL</u>	<u>sch 40</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation Factory perf well points  
 Size perforation .070  
 From 20' feet to 18' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-13 1000  
 Date completed 3-14 1000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>Appx 65</u>	<u>0</u>	<u>20 min</u>

9. WATER LEVEL  
 Static water level 4' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Foot Hill Eng & Dewatering Contractor  
 Address 905 E. Third St. CORONA, Ca 91719 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board. 0035906  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M 2119  
 Signed Steve J. Smith  
 By driller performing actual drilling on site or contractor  
 Date 3-13-00