Fifth Elev 1400 x 8.00 = [illegible]

WHITE—DIVISION OF WATER RESOURCES
[redacted]ARY—CLIENT'S COPY
[redacted]INK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79842
Permit No. DW 1112
Basin 212

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS PAVING CORP
MAILING ADDRESS 4420 S. DECATUR LAS VEGAS, NV 89103
ADDRESS AT WELL LOCATION Encl of E. Sunset Rd & Las Vegas Wash

2. LOCATION SW 1/2 S 1/2 Sec. 30 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. DW 1112 (Issued by Water Resources) | 160-30-003 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other well points

4. dewater PROPOSED USE Dewatering
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other well points

6. ~~[illegible]~~ LITHOLOGIC LOG

228-285 Material	Water Strata	From	To	Thickness
1. Silty Sand (SM) Porous, medium dense, Brown	4'	0	5	5'
2. Poorly Graded Gravel w/Sand (GP) Medium dense gray to black	4'	5'	12'	7'
3. Silty Sand (SM) Fine Gray, medium dense, gray	4'	12	16'	4'
Poorly Graded Gravel with Silt & Sand (GP-GM)	4'	16'	20'	4'

Date started 3-13, 1900
Date completed 3-14, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	Appx 65	-0-	20 min

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE)
2" Inches From 0 Feet To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	20

Perforations:
Type perforation Factory perf well points
Size perforation .070
From 20' feet to 18' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foot Hill Eng & Dewatering (Contractor)
Address 905 E. Third St. (Contractor)
Corona, Ca 91719
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2119
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-13-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627