

OFFICE USE ONLY  
 Log No. 79849  
 Permit No. DW 1112  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION END OF E. SUNSET Rd # LAS VEGAS WASH  
 MAILING ADDRESS 4470 S. DELAWARE LAS VEGAS, NV 89103  
 2. LOCATION SW 1/4 S 1/2 Sec. 30 T. 21 N/S R. 63 E. CLARK County  
 PERMIT NO. DW 1112 Issued by Water Resources | 160-30-003 Parcel No. | Subdivision Name

3. ~~300-400~~ WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other well point  
 4. PROPOSED USE dewater  
 Domestic  Irrigation  Test  Monitor  Stock  
 Municipal/Industrial  Air  Other well points

6. 342-400 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1. 5.1/4 Sand w/ gravel (SM) dense, light brown</u>	<u>4</u>	<u>0'</u>	<u>3'</u>	<u>3'</u>
<u>2. clayey sand w/ gravel (SC) med. dense brown</u>	<u>4'</u>	<u>3'</u>	<u>13'</u>	<u>10'</u>
<u>3. poorly graded sand w/silt (SP-SM) very large cobbles</u>	<u>4'</u>	<u>13'</u>	<u>20'</u>	<u>7'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 20' Feet Depth Cased 17'-20' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2 Inches 0 Feet 20 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>well points</u>	<u>20</u>

Perforations:  
 Type perforation Factory PER well point  
 Size perforation 200  
 From 20 feet to 18' feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

Date started 3-17-00  
 Date completed 3-20-00

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>TRASH</u>	<u>pump</u>	<u>Appx. 65-70</u>	<u>20 min</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Foothill Eng. & Dewatering Contractor  
 Address 903 E. THIRD ST. COLONA, CA 91719 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0035906  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-21-00