

OFFICE USE ONLY
Log No. 79933
Permit No. _____
Basin. 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40768

1. OWNER Lee Hill ADDRESS AT WELL LOCATION at the mouth of Wilson Canyon, Hwy 208
MAILING ADDRESS _____
2. LOCATION 1/4 SW 1/4 Sec 9 T 11 N/S R 25 E Lyon County _____
PERMIT NO. 04-391-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Gravel		1	6	6
Clay		23	31	8
Siltstone		31	33	2
Clay		33	35	2
Bedrock	X	33	315	

8. WELL CONSTRUCTION
Depth Drilled 315 Feet Depth Cased 315 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 1/8 Inches 1 Feet 130 Feet
6 1/2 Inches 130 Feet 315 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/8</u>	<u>133/15 lb</u>	<u>0.250</u>	<u>1</u>	<u>130</u>
<u>5 1/2</u>	<u>200</u>	<u>0.250</u>	<u>130</u>	<u>315</u>
		<u>5/16</u>	<u>115</u>	<u>130</u>

Perforations:
Type perforation Impulse Pump
Size perforation 3/16" 5 x 1/4" Screen
From 110 feet to 130 feet
From 130 feet to 315 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature C °F Quality Good

Date started 2/12/00, 19_____
Date completed 2/25/00, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35-40</u>		<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jason Daulton Contractor
Address P.O. Box 799 Contractor
59 NW 25420
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1826
Signed _____
By driller performing actual drilling on site or contractor
Date 3/2/00