


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 79935
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.240

NOTICE OF INTENT NO. 43094

1. OWNER PINE NUT CONSTRUCTION ADDRESS AT WELL LOCATION 1201 QUAIL RIDGE CV, NV 89410
 MAILING ADDRESS 1319 JACOBSEN LN CV, NV 89410

2. LOCATION SE 1/4 SE 1/4 Sec. 4 T 12 S R 19 E DOUGLAS County
 PERMIT NO. 19 051 37 QUAIL RIDGE

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DG + BOULDERS</u> <u>GRAY + BLACK</u>		<u>0</u>	<u>60</u>	<u>60</u>
<u>DG WITH OCCASIONAL</u> <u>BOULDERS</u>		<u>60</u>	<u>160</u>	<u>100</u>
<u>BROWN</u> <u>DG WITH CLAY +</u> <u>WHITE QUARTZ SAND</u>		<u>160</u>	<u>240</u>	<u>80</u>
<u>DG WITH CLAY</u> <u>+ REDDISH RIOLITE</u> <u>SAND</u>	<input checked="" type="checkbox"/>	<u>240</u>	<u>265</u>	<u>25</u>
<u>BROKEN RIOLITE</u> <u>PURPLISH</u>	<input checked="" type="checkbox"/>	<u>265</u>	<u>302</u>	<u>37</u>

8. WELL CONSTRUCTION
 Depth Drilled 302 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From 105/8 Inches To 0 Feet
302 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>		<u>0.188</u>	<u>+2</u>	<u>260</u>

Perforations:
 Type perforation Factory slot
 Size perforation 3/32
 From _____ feet to _____ feet
 From 260 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level: 170 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 54 °F Quality good

Date started 1-5 _____
 Date completed 1-26 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA DRILLING INC Contractor
 Address 75 LEWERS CREEK RD Contractor
CARSON CITY NV 89704

Nevada contractor's license number 13697A
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller.

Signed John D. Reich
 by driller performing actual drilling on site or contractor

Date 3-24-00