WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79937
Permit No.
Basin 103

NOTICE OF INTENT NO. 41926

1. OWNER Kim Posnien
MAILING ADDRESS 440 Foothills Rd. Gardnerville NV. 89410
ADDRESS AT WELL LOCATION 750 Parchman Ct. Gardnerville NV. 89410

2. LOCATION NW ¼ NW ¼ Sec. 36 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 19-440-090 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Cobbles and Cemented Gravels		3	37	34
DG Sands and Gravels		37	75	38
Brown Clay		75	84	9
Coarse Sands and Clay Seams	X	84	143	59
Fractured Basalts and obsidian Gravels	XX	143	160	17

Date started 3-13, 1900
Date completed 3-16, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	25	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2905
Signed Michael Hoel (By driller performing actual drilling on site or contractor)
Date 3-16-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627