WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79941
Permit No.
Basin 105

NOTICE OF INTENT NO. 43069

1. OWNER Westridge Homes Inc
MAILING ADDRESS 1521 B Hwy 395 Su 215 Gardnerville, NV 24
ADDRESS AT WELL LOCATION 622 Stagecoach Rd Gardnerville, NV

2. LOCATION NE ¼ NE ¼ Sec 22 T 12 N/S R 20 E Douglas County
PERMIT NO. SE SE (Issued by Water Resources) 1220-24-810-023 (Parcel No.) Rhuenstroth (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay & Boulders		0	12	12
Sand & Gravel		12	97	85
Sandy Clay & Gravel		97	153	56
Cemented Boulders		153	177	24
Sand & Gravel		177	235	58
Sandy Clay		235	243	8
Sand & Gravel		243	259	16
Cemented Gravel		259	278	19
Gravel	✓✓	278	300	22

Date started 5-2-00, 19
Date completed 5-11-00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	+25		1 hr

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	60 Feet
9 7/8	Inches	60 Feet	300 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	300

Perforations:
Type perforation Factory Milled
Size perforation 1/8 x 3
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 147 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed (By driller performing actual drilling on site or contractor)
Date 5-12-00

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627