WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79947
Permit No.
Basin 105

NOTICE OF INTENT NO. 41933

1. OWNER Jack White
MAILING ADDRESS 489 Clair Ct
Gardnerville NV 89410

ADDRESS AT WELL LOCATION 228 Laura Springs
Gardnerville NV 89410

2. LOCATION NW ¼ NW ¼ Sec. 34 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 17-310-06 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Black Silty Sands	x	3	43	40
Brown Clay		43	61	18
Brown and Rusty DG Sands w/ Clay Stringers		61	94	33
Gray Clay		94	110	16
Brown Rusty Clay		110	130	20
Coarse DG Sands Obsidian DG	xx	130	160	30

Date started 4/19, 19 00
Date completed 4/20, 19 00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	48	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 3/4	0 Feet	160 Feet
	Feet	Feet
	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3X 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 4 G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Dr. (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/25/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627