WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79962
Permit No.
Basin 104

NOTICE OF INTENT NO. 44423

1. OWNER Carson City Parks & Recreation
MAILING ADDRESS 3303 Butti Way Bldg #9
Carson City, NV 89701

ADDRESS AT WELL LOCATION 801 Old Clear Creed Rd.

2. LOCATION S1/2 SW1/4 SE 1/4 Sec. 31 T 15N N/S R 20E E Carson County
PERMIT NO. 27478 (Issued by Water Resources) | 009-303-02 (Parcel No.) | Subdivision Name

3. WORK PERFORMED: [ ] New Well [ ] Replace [ ] Recondition [ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 8" x 10 gauge well. We flushed out the bottom fill from 76-80'. We then pumped 1.75 cu yards neat cement mixed 5.2 gallons per sack from bottom to top. No perforations were done per Tom Gallagher due to the 50' sanitary seal and perforations already 60-80'. After pumping the 1.75 cu. yards, the cement dropped down to 18'. We then added 3/4 yards 6 sack cement grout. Again the level dropped to 14' and we added approximately 1/2 additional cement grout.				
See log 107599 for possible orig. completion				

Date started 5/8/2000, 19__
Date completed 5/9/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	80	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 1/8		10 gauge	0	80

Perforations:
Type perforation
Size perforation
From 60 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [X] Poured

Seal Type: [X] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL

Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 5/9/00

USE ADDITIONAL SHEETS IF NECESSARY