WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79965
Permit No.
Basin 87

NOTICE OF INTENT NO. 43589

1. OWNER Bruno Benna
MAILING ADDRESS 8500 Deringer Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION Deringer Lane
Reno,Nevada

2. LOCATION NE 1/4 NE 1/4 Sec. 12 T 18N N/S R 19E E Washoe County
PERMIT NO. 61664 (Issued by Water Resources) 040-401-02 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	15
Rock		15	35	20
Sand and clay		35	170	135
Gravel		170	190	20
Sand and Clay		190	260	70
Sand and streaks of gravel	x	260	325	65
T.D. 321 1/4 inch metal plate on bottom				

Date started 03/09/2000, 19__
Date completed 03/17/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
170	318	5 hours

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 321 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4	Inches	0 Feet	325 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.94	.188	+1-1/2	321

Perforations:
Type perforation Wire wrap screen
Size perforation .050 slot
From 170 feet to 190 feet
From 301 feet to 321 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 321 feet

9. WATER LEVEL
Static water level 2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada
Nevada contractor's license number issued by the State Contractor's Board 0035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786
Signed Larry Wells (By driller performing actual drilling on-site or contractor)
Date 03/24/2000

USE ADDITIONAL SHEETS IF NECESSARY