

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42538

1. OWNER GALENA WATER ENTERPRISES ADDRESS AT WELL LOCATION 4.5 MILES UP MOUNT ROSE HIGHWAY FROM HIGHWAY 395 ON SOUTH SIDE OF ROAD
 MAILING ADDRESS C/O RANDY BOWLING CONSULTING
PO BOX 12926/RENO, NV/89510

2. LOCATION NE 1/4 SW 1/4 Sec 35 T 18 N/S R 19 E WASHOE County
 PERMIT NO. 61269 & 61270 150-102-01 NOT APPLICABLE
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL, COBBLES AND BOULDERS		0	160	
SAND, GRAVEL, COBBLES BOULDERS WITH VOLCANICS, MINOR CLAY		160	310	
RED AND BLACK VOLCANIC ROCK, SANDY CLAY, GRANITE		310	404	
BLACK AND RED VOLCANICS, SAND, CLAY		404	673	
BLACK ROCK WITH SANDY BROWN CLAY, FRACTURED ROCK WITH VOLCANICS		673	735	

8. WELL CONSTRUCTION
 Depth Drilled 735 Feet Depth Cased 715 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
32 Inches 0 Feet 157 Feet
22 Inches 157 Feet 735 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	0	715

Perforations:
 Type perforation WIRE WRAP SCREEN
 Size perforation 0.065
 From 440 feet to 540 feet
 From 560 feet to 710 feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 157' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 735 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LAYNE CHRISTENSEN COMPANY Contractor
 Address 275 COUNTY ROAD 98 Contractor
WOODLAND, CA 95695
 Nevada contractor's license number 0019101
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2141
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date APRIL 12, 2000

Date started JANUARY 20, 2000
 Date completed MARCH 25, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	250	47