WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79969
Permit No.
Basin 87

NOTICE OF INTENT NO. 38050

1. OWNER Chris Johnson
MAILING ADDRESS 14430 Spezia
Reno, NV 89511

ADDRESS AT WELL LOCATION 14430 Spezia

2. LOCATION SE 1/4 NE 1/4 Sec. 30 T 18N N/S R 20E E Washoe County
PERMIT NO. WaCo#6543 Issued by Water Resources | 049-371-48 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" domestic well by first perforating the casing from static water level of 235' to 180'. We then pumped 4.5 yards of neat cement mixed 5.2 gallons/sack of cement from top of well to bottom using pressure grout machine and tremie pipe. We cut the top well casing off about 1.5' below surface. The perforations were done by Mills Knife at four around and at 1 foot intervals.				

Date started 03/15/2000 , 19__
Date completed 03/15/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	460

Perforations:
Type perforation Mills knife
Size perforation
From 235 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed [ ] Yes [X] No
From feet to feet

9. **WATER LEVEL**
Static water level 235 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1602 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
by driller performing actual drilling on-site or contractor
Date 03/15/2000

USE ADDITIONAL SHEETS IF NECESSARY