WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79977
Permit No.
Basin 92A

NOTICE OF INTENT NO. 43860

1. OWNER MALCOLM ST'PIERRE
MAILING ADDRESS 11270 Andes Street
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Adobe Drive
Reno, Nevada 89506

2. LOCATION NW ¼ NW ¼ Sec. 13 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 087-060-19 (Parcel No.) Silver Knolls Area (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown moist clay		1	5	4
BRown sandy clay		5	16	11
Coarse granite sands		16	18	2
Brown sandy clay		18	61	43
Soft zone (NO WATER)		61	64	3
Brown sandy clay		64	129	65
Soft zonr (NO WATER)		129	135	6
Brown sandy clay		135	209	74
Soft zone (NO WATER)		209	212	3
Brown sandy clay		212	235	23
Soft zone	X	235	292	57
Brown sandy clay		292	300	8

Date started May 06, 2000
Date completed May 10, 2000

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 235 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 209 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date May 11, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627