

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 79990
 Permit No. 92A
 Basin 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 42823

1. OWNER TAMMY SWEDIN
 MAILING ADDRESS 15000 Red Rock Road
Reno, Nevada 89506
 ADDRESS AT WELL LOCATION Same
 2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 18 T. 22N
 PERMIT NO. 079-362-01 N/S R. 19 E. Washoe County
 Issued by Water Resources Parcel No. Red Rock Estates # 79
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	13	12
Brown sandy clay		13	21	8
Brown clay		21	48	27
Brown sandy clay		48	112	64
Brown sandy clay with small gravels		112	166	54
Gray sandy clay		166	193	27
Soft zone (WET CLAY)		193	215	22
Gray sandy clay		215	241	26
Soft zone	X	241	260	19
Gray sandy clay		260	279	19
Soft zone	X	279	287	8
Gray sand and clay		287	320	33
Soft zone	X	320	331	11
Gray sandy clay		331	350	19

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 50 Feet
8 5/8 Inches 50 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>350</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 265 feet to 305 feet
 From 325 feet to 345 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50 feet Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 350 feet

9. WATER LEVEL
 Static water level 209 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 7, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		

Date started April 4, 2000 XX
 Date completed April 6, 2000 XX
19

RECEIVED
 APR 11 AM 11:21
 STATE ENGINEERS DIVISION