WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79999
Perm No.
Basin 54

NOTICE OF INTENT NO. 43807

1. OWNER Carrie Dann
MAILING ADDRESS Unit 1 Box 11
Beowawe, NV 89821

ADDRESS AT WELL LOCATION Hand-Me-Down Creek
Quadrangle-Nevada-Eureka
County

2. LOCATION NW 1/4 NE 1/4 Sec. 33 T 29N N/S R 49E E Eureka County
PERMIT NO. _____ Issued by Water Resources
005-490-30 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sandy Clay		4	17	13
Gravel/sandy clay		17	75	58
Gravel w/clay stringers		75	110	35

RECEIVED 00 APR 27 AM 11:40 WATER ENGINEERING OFFICE

Date started 4/22/00, 19__
Date completed 4/22/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 Hour

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
9 1/2 Inches		50 Feet	110 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	100

Perforations:
Type perforation Single Row Mill Slot
Size perforation 3 x 1/8
From 80 feet to 100 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 110 feet

9. WATER LEVEL
Static water level 29 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140

Signed Jeri A. Tompk
By driller performing actual drilling on-site or contractor

Date 4/25/00