


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **43614**

1. OWNER **Barrick Goldstrike Mines VD98-2** ADDRESS AT WELL LOCATION **Barrick Goldstrike**
 MAILING ADDRESS **P.O. Box 29** **minesite, north of Carlin, NV.**
Elko, NV 89803

2. LOCATION **SE** 1/4 **NW** 1/4 Sec. **19** T **36N** N/S R **50E** E **Eureka** County
 PERMIT NO. **55141** issued by Water Resources Parcel No. **N/A** Subdivision Name **N/A**

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned by pumping super plug from T.D. to 650', placed hole plug from 650' to 20', and capped with 20' of neat cement.				
Quantities Used: Super Plug=72 cu. ft. Hole Plug=125 cu. ft. Cement = 5 cu. ft.				

8. WELL CONSTRUCTION
 Depth Drilled **890** Feet Depth Cased **878** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17.75 Inches	0	40
10 Inches	40	890

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.250	44.86	0.325	0	40
6.625	17.02	0.250	0	878

Perforations:
 Type perforation **Roscoe Moss Full Flo Louver**
 Size perforation **0.125"**

From	To
138	158
178	198
238	878

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal **52'**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From **52** feet to **890** feet

9. WATER LEVEL
 Static water level **Dry** feet below land surface
 Artesian flow **N/A** G.P.M. **N/A** P.S.I.
 Water temperature **N/A** °F Quality **N/A**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Lang Exploratory Drilling** Contractor

Date started **5/13/2000**, 19
 Date completed **5/13/2000**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address **P.O. Box 5279** Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board **0021976**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1410**
 Signed **John Verguts** By driller performing actual drilling on-site or contractor
 Date **5/15/2000**