



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19083

1. OWNER Bill Walsh ADDRESS AT WELL LOCATION: 1501 W. Huckleberry St, Reno NV, 89048  
 MAILING ADDRESS: 1501 W. Huckleberry St, Reno NV, 89048  
 2. LOCATION NE 1/4 NW 1/4 Sec 29 T. 20 N. R. 53 E. Nye County  
 PERMIT NO. 39-032-11 Parcel No. Calvada Valley Unit 9B Subdivision Name

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE:  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE:  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	5'	5'
white clay		5'	15'	10'
brown clay		15'	30'	15'
caliche		30'	35'	5'
brown clay		35'	50'	15'
white clay		50'	65'	15'
caliche		65'	70'	5'
brown clay		70'	95'	25'
caliche		95'	100'	5'
white clay		100'	125'	25'
brown clay		125'	140'	15'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 140 Feet  
12 Inches 0 Feet 140 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Saw cut  
 Size perforation 1/8" x 3"  
 From 100 feet to 140 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started May 8 2000  
 Date completed May 12 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lobue Construction Co. Contractor  
 Address 4191 S. Jackie St. Reno NV 89048  
 Nevada contractor's license number 0049225  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116  
 Signed Forrest Lobue  
 By driller performing actual drilling on site or contractor  
 Date June 8, 2000