

OFFICE USE ONLY
Log No. 80059
Permit No. DW 1112
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION END OF E. SUNSET
MAILING ADDRESS 4420 S. DECATUR Road & LAS VEGAS WASH
LAS VEGAS, NV 89103
2. LOCATION SW 1/4 S 1/4 Sec. 30 T 21 N/S R 63 E CLARK County
PERMIT NO. DW 1112 Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other well points
4. Dewater PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other well points

6. ~~2-57~~ LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1. <u>Silty Sand w/Gravel (S.G.) dense light brown, slightly moist.</u>	<u>4'</u>	<u>0</u>	<u>12</u>	<u>12'</u>
2. <u>LEAN CLAY (CL) POROUS STIFF, BROWN wet</u>	<u>4'</u>	<u>12'</u>	<u>18'</u>	<u>6'</u>
3. <u>Sandy LEAN CLAY (CL) Very Stiff, gray, wet</u>	<u>4'</u>	<u>18'</u>	<u>19'</u>	<u>1'</u>
<u>Cemented Sand & Gravel - Hard, Gray</u>	<u>4'</u>	<u>19'</u>	<u>21'</u>	<u>2'</u>

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 17'-20' Feet
HOLE DIAMETER (BIT SIZE) well points size
From 2 Inches To 0 Feet 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>DUC</u>	<u>Sch 40 well points</u>	<u>0</u>	<u>20</u>

Perforations:
Type perforation FACTORY PERF well point
Size perforation .070
From 20' feet to 18' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
Depth of Seal _____
Placement Method: Pumped Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality Good

Date started 3-2 1900
Date completed 3-2 1900 SSS

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>TRASH PUMP</u>	<u>65</u>	<u>20 min</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FOOTHILL ENG. & DEWATERING Contractor
Address 905 E. THIRD ST. COCONA, CA 91719 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2119
Signed [Signature]
By driller performing actual drilling on site or contractor.
Date 3-6-00