

FIRST 2100, 1700 & 0

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 80063  
Permit No. DW 1112  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41739

1. OWNER LAS VEGAS DRAINING ADDRESS AT WELL LOCATION END OF E. STREET  
MAILING ADDRESS 4420 S. DECATUR ROAD LAS VEGAS WASH  
LAS VEGAS, NV 89103

2. LOCATION SW 1/4 S 1/2 Sec. 30 T. 21 N/S R. 65 E. CLARK County  
PERMIT NO. DW 1112 Parcel No. 160-30-003 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other Well points

4. PROPOSED USE  
 Dewater  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Well points

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
1. Silty Sand w/Gravel (S.M.) dense light Brown, Slightly moist.	4'	0	12	12'
2. Lean Clay (CL) Porous, stiff, brown wet	4'	12'	18'	6'
3. Slightly Lean Clay (CL) Very stiff, gray, wet	4'	18'	19'	1'
4. Cemented Sand & Gravel - Hard, gray	4'	19'	21'	2'

8. WELL CONSTRUCTION  
Depth Drilled 20' Feet Depth Cased 17'-20' Feet

HOLE DIAMETER (BIT SIZE) well points size  
From 2 Inches 0 Feet 20 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	DUC	Sch 40 well points	0	20

Perforations:  
Type perforation FACTORY PERF well point  
Size perforation .010  
From 20' feet to 18' feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 4' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality Good

Date started 3-2 1900  
Date completed 3-2 1900

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
TRASH PUMP	65	6	20 min

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name FOOTHILL ENG. & DEWATERING Contractor  
Address 905 E. THIRD ST. CORONA, CA 91719  
Nevada contractor's license number issued by the State Contractor's Board 0035906  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M2119  
Signed Stan J. Smith  
By driller performing actual drilling on site or contractor  
Date 3-6-00