WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80090
Permit No.
Basin 162

NOTICE OF INTENT NO. 19088

1. OWNER Dave Gerow
MAILING ADDRESS 5060 E. Navajo Blvd
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 5060 E. Navajo Blvd.
Pahrump, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 21 N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 45-351-10 Subdivision Name Kellogg Ranch Estates #2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	10'	10'
white clay		10'	15'	5'
brown clay		15'	25'	10
sand/gravel		25'	75'	50'
caliche		75'	85'	10'
brown clay		85'	100'	15'
caliche		100'	105'	5'
brown clay		105'	130'	25'
white clay		130'	140'	10'
brown clay		140'	150'	10'

Date started June 2, 2000
Date completed June 15, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	150 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	150

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 150' feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date June 19, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627