WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80399
Permit No.
Basin 207

NOTICE OF INTENT NO. Lot

1. OWNER Milton Judd
MAILING ADDRESS Po Box HC 34 Box 34120 Ely NV 89301
ADDRESS AT WELL LOCATION Lot 8 Block 4

2. LOCATION SW ¼ SE ¼ Sec. 12 T. 12 N/S R. 61 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 013-025-07 (Parcel No.) Preston town site Survey (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	
Cemented gravel		1	3	
Clay		3	5	
gravel clay conglomerate		5	20	
clay con		20	24	
gravel con.		24	35	
clay con.		35	42	
gravel con		42	52	
clay		52	65	
clay gravel con		65	75	
gravel con	water	75	80	
clay con		80	86	
gravel	water	86	88	
clay con		88	95	
gravel con	water	95	105	
clay con.		105	115	
gravel con	water	115	120	

Date started June 6, 2000
Date completed June 20, 2000

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	1	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
8 Inches		60 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.9	.188	4	120

Perforations:
Type perforation Mill
Size perforation ⅛ x 2.5" x 6 row
From feet to feet
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 120 feet

9. WATER LEVEL
Static water level 71 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvan R Maynard (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date July 24-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627