WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80483
Permit No.
Basin 103

NOTICE OF INTENT NO. 41998

1. OWNER Tom Redcan
MAILING ADDRESS Carson City NV
ADDRESS AT WELL LOCATION 16 Baldwin Ln.
Dayton NV.

2. LOCATION SW ¼ SW ¼ Sec. 26 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 16-262-01 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	6	6
Course DG Sands and Imbedded Gravels		6	27	21
Hard Fractured DG Granite.		27	142	115
Fractured Rusty Granite medium	x	142	150	8
Hard Black Slate		150	171	21
Soft Zone Volcanic Sands	xx	171	182	11
Hard Blue Gray Granite		182	190	8

Date started 7-24, 1900
Date completed 7-28, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	29	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12½ Inches		0 Feet	190 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.21	1/188	0	190

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 190 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-30-00

RECEIVED 00 AUG -4 AM 10:18

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627