WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81038
Permit No.
Basin 107

NOTICE OF INTENT NO. 27327

1. OWNER Kim Stewart
MAILING ADDRESS P.O. Box 234
Smith NV 89430

ADDRESS AT WELL LOCATION 161 Day Lane
Smith NV 89430 Log #505
well #29 State engineer map

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. 12156 (Issued by Water Resources) 10-431-13 (Parcel No.) well #2 Application map (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Propagation
☒ Domestic + Fish ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drilled 6¼" Hole To Loosen 3½" Casing Found Inside 7⅞ Casing				
Top Soil - Clayish		0	2	2
Coarse Sand - Gravel		2	15	13
Brown Clay		15	63	48
Old Hole - Open		63	73	10
Old Hole - Fine Sand		73	93	20
Old Hole - Sand-Gravel		93	103	20
Circulation in 7⅞ casing at 63'				
Circulation in 3½ Casing at 93'				
Removed 103' 3½" casing				
7⅞ Casing won't Pull				
Preforate 7⅞ To 33' Casing moved				
Cleaned Hole To 103'				
Pumped 19 Bags Abantonite From 103' To Surface				
Removed 48' 4" 7⅞" Casing				
Pumped 6 Bags Cement + 12 Bags Redi-mix Cement Grout To Surface				
Over Night Settled Back To 5'				
Poured 10 Bags Redi-mix Concret				
- Note -				
After Pulling 7⅞ casing Hole was clean Back To 10' for Surface Plug				

Date started 7-11 2000
Date completed 7-21 2000

7. Old WELL ~~TEST~~ DATA

~~TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift~~

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Static	6"		
Open Hole Between 7⅞" + 3½ 73'			
Open Hole inside 3½" 103'			

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 48' 4" Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Old	7¼ Inches	0 Feet	88 Feet
New	6¼ Inches	0 Feet	103 Feet To Loosen Pipe
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7⅞	12	5/16	+1	47' 4"
3½	—	Sch 40	+18	101' 6"
all	aboved	Pipe	Removed	

Perforations:
Type perforation Holt Preforater
Size perforation ¼" x 1" x 4 Rows 5 Slot per. Ft.
From 0 feet to 33 feet
From Before feet to Removal feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Total 103'
Placement Method: ☒ Pumped ☒ Poured To Top off
Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

Seal Type:
☐ Neat Cement
☒ Cement Grout 10'
☐ Concrete Grout
12.1 % Bentonite 10' To 103'

9. WATER LEVEL
Static water level Start 6" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality Old well Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Drilling / DBA (Contractor)
Address 152 N. B. Bee Lane (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-14-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627