

MW-2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 81058
Permit No. _____
Basin. 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44103

1. OWNER Park Cattle Company, Inc
MAILING ADDRESS 1300 Buckeye Rd
Minden, NV 89423
ADDRESS AT WELL LOCATION Maeller Lane
Douglas Co.
2. LOCATION SW 1/4 SW 1/4 Sec. 14 T. 13 N. S. R. 19 E. Douglas County
PERMIT NO. N/A Issued by Water Resources Parcel No. 17-190-61 Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DARK BROWN SILTY CLAY (CH) SOFT MOIST</u>		<u>0.2</u>	<u>1.0</u>	<u>1.0</u>
<u>BR CLAY (CH) STIFF, MOIST.</u>		<u>1.0</u>	<u>4.0</u>	<u>3.0</u>
<u>COLOR CHANGE TO GREY BELOW 4.0</u>		<u>4.0</u>	<u>13.0</u>	<u>9.0</u>
<u>STABLE WATER LEVEL</u>	<u>4.5'</u>			
<u>WATER 1st ENCOUNTERED</u>	<u>18.0</u>			
<u>BROWN SAND (SP) MEDIUM DENSE SATURATED</u>		<u>13.0</u>	<u>24.0</u>	<u>11.0</u>

8. WELL CONSTRUCTION
Depth Drilled 24.0 Feet Depth Cased 19.0 Feet
HOLE DIAMETER (BIT SIZE)
7.3/4 Inches From 0.0 Feet To 24.0 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.70/ft</u>	<u>0.308</u>	<u>0.0</u>	<u>4.0</u>

Perforations:
Type perforation SLOTTED
Size perforation 0.620
From 4.0 feet to 19.0 feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet
Surface Seal: Yes No Seal Type:
Depth of Seal 0.0 - 1.0 Neat Cement
Placement Method: Pumped bentonite Cement Grout
 Poured (1.0 - 3.0) Concrete Grout
sand & gravel
Gravel Packed: Yes No
From 3.0 feet to 24.0 feet

9. WATER LEVEL
Static water level 4.0 feet below land surface
Artesian flow.....G.P.M.....P.S.I.
Water temperature 6.2 °F Quality Silty & cloudy

Date started MAY 26TH, 2000
Date completed MAY 26TH, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DAVE LEHMAN w/ PEZONELLA ASSOC Contractor
Address 520 EDISON WAY Contractor
RENO, NV 89502
Nevada contractor's license number issued by the State Contractor's Board N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
Signed Dave Lehman
By driller performing actual drilling on site or contractor
Date 5/31/00