

OFFICE USE ONLY
 Log No. 81070
 Permit No. 88
 Basin. 88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43975

1. OWNER JIM ZOELLIN ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 430 Andrew Lane
Reno, Nevada 89511

2. LOCATION NW 1/4 NE 1/4 Sec 9 T. 17N N/S R. 20 E Washoe County
 PERMIT NO. 017-350-50 Steamboat Area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	33	31
Cemented sands		33	41	8
Rusty brown clays		41	52	11
Yellow clay w/gravels		52	54	2
Brown clay w/gravels		54	63	9
Soft brown sandy clay		63	68	5
Yellow clays		68	73	5
Cemented brown sand		73	76	3
Weathered volcanic rock		76	86	10
Purple to gray volcanic		86	115	29
Fracture rock	X	115	123	8
Gray volcanic		123	133	10
Fracture	X	133	135	2
Gray volcanic rock		135	143	8
Fracture rock	X	143	153	10
Gray volcanic rock		153	180	27

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 180 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	180

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 140 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow G.P.M. 60+ P.S.I.
 Water temperature cold °F Quality clear

Date started July 25, 2000 XX
 Date completed July 26, 2000 XX

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60+		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370
RENO, NEVADA 89510 Contractor

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date August 10, 2000