

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 81154
Permit No. 87
Basin.

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 13628

1. OWNER Vista Canyon Group ADDRESS AT WELL LOCATION Sparks Marina Park Lake South Side
MAILING ADDRESS 1100 Town & Country Rd. Orange, CA 92868
2. LOCATION SW 1/4 NW 1/4 Sec. 10 T. 19 S R. 20 F. Washoe County
PERMIT NO. 37-030-25 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other.
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Test, Stock.
5. WELL TYPE: Cable, Rotary, RVC, Air, Other.

6. LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Rows include: Brown silt & sand fill, Silty Gravel, Sandy gravel, Brown fine sand, Dk. gray sandy gravel, Brown sand, Dk. gray sandy gravel, Brown sand with some gravel, Brown clay silt, Sand and gravel, Fine sand, silt, Gravel with some sand, Sandy silt, Gravel, sand, cobbles, Gravel sand, Gravel, some sand, Brown sandy silt, Gravel, some sand, Fine to coarse sand, Fine to coarse gravel, Brown clay.

8. WELL CONSTRUCTION: Depth Drilled 101 Feet, Depth Cased 99 Feet. HOLE DIAMETER (BIT SIZE) table with columns: From, To, Inches, Feet. Rows: 14-3/4 Inches -0- Feet 10 Feet, 9-7/8 Inches 10 Feet 101 Feet.

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Rows: 4.5 PVC Sch40 -0- 79, 4.5 PVC Sch40 79 99.

Perforations: Type perforation Mill Slot, Size perforation 0.50. From 79 feet to 99 feet.

Surface Seal: Yes, No. Seal Type: Neat Cement, Cement Grout, Concrete Grout.
Depth of Seal 72.5
Placement Method: Pumped, Poured.
Gravel Packed: Yes, No. From 72.5 feet to 101 feet.

9. WATER LEVEL: Static water level 17 feet below land surface. Artesian flow no. G.P.M. P.S.I. Water temperature cold °F Quality clear.

Date started April 26, 2000, Date completed May 11, 2000.

7. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Time (Hours).

10. DRILLER'S CERTIFICATION: This well was drilled under my supervision and the report is true to the best of my knowledge. Name Donald Stratton for Beylik Drilling Contractor. Address 555 S. Harbor Blvd. La Habra, CA 90631-6124. Nevada contractor's license number 0007055A. Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011. Signed [Signature] By driller performing actual drilling on site or contractor. Date June 29, 2000.