WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81177
Permit No. 28828
Basin 230

NOTICE OF INTENT NO. 44801

1. OWNER Bonnie Wahl
MAILING ADDRESS Adobe Rd. Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION Adobe Rd Amargosa Valley, NV 89020

2. LOCATION SE ¼ NW ¼ Sec. 35 T. 16 N/S R. 49 E. Nye County
PERMIT NO. 28828 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	21	
Hard limestone		21	27	
Limestone layered Clay		50	53	
Clay beds of Sand & gravel		53	65	
Clay & gravel		65	90	
Gravel	1st	90	100	
Clay sand & gravel		100	125	
Sand & gravel		125	170	
Gravel	2nd	170	175	
Sand & gravel		175	200	
Bottom of Hole			200	

Date started Aug 16 2000, 19
Date completed Aug 19, 2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
17½	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	PVC			
Surface Protective Casing 6"x10" Steel .1808 Wall				

Perforations:
Type perforation Machined - factory
Size perforation Cut
From 100' feet to 200' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 200' feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address HCR 69 Box 452 (Contractor)
Amargosa Valley NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 09-15-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627