WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

Dual Completion

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81324
Permit No.
Basin 61

NOTICE OF INTENT NO. 43624

OWNER Barrick Goldstrike Mines PZ00-1
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
Minesite, North of Carlin, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 19 T 36N N/S R 50E E Eureka County

PERMIT NO. N/A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Green grey rock with		0		
calcite			40	40
Brown red rock		40	60	20
Green grey rock with		60		
brown			100	40
Fractured black rock		100	120	20
Light green rock with		120		
calcite			240	120
Grey rock		240	280	40
Light green rock with		280		
calcite			340	60
Black rock with		340		
calcite			360	20
Green grey rock		360	400	40
Construction Detail:				
Cement		0	50	50
Hole Plug		50	210	160
Gravel Pack		210	250	40
Hole Plug		250	260	10
Cement		260	265	5
Hole Plug		265	290	25
Gravel		290	330	40
Hole Plug		330	400	70

Date started 7/6/2000, 19__
Date completed 7/10/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	127'	1 Hour

8. WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14.75	Inches	0	Feet	20	Feet
8.25	Inches	20	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	28.04	0.250	+2	20
1: 2.375	5.02	0.218	+1	320
2: 2.375	5.02	0.218	+1	240

Perforations:
Type perforation Slot
Size perforation 0.125"

From 220' feet to 240' feet
From 320' feet to 360' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1: 290 2: 210 feet to 1: 300 2: 250 feet

9. WATER LEVEL
Static water level 1: 218 2: Dry feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2047
Signed Michael VanLacker (By driller performing actual drilling on-site or contractor)
Date 7/17/2000

USE ADDITIONAL SHEETS IF NECESSARY

B.ST.