

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19103

1. OWNER Dave Flynn ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3331 S. Winchester Ave. Pahrump, Nevada 89048 ADDRESS 3331 S. Winchester Ave. Pahrump, Nevada 89048
2. LOCATION SE 1/4 NW 1/4 Sec. 32 T. 20 N. R. 53 E. Nye County Nye
PERMIT NO. 40-530-01 Parcel No. _____ Subdivision Name Caluda Valley Unit 5

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown clay</u>		<u>0'</u>	<u>5'</u>	<u>5'</u>
<u>white clay</u>		<u>5'</u>	<u>15'</u>	<u>10'</u>
<u>caliche</u>		<u>15'</u>	<u>20'</u>	<u>5'</u>
<u>white clay</u>		<u>20'</u>	<u>45'</u>	<u>25'</u>
<u>caliche</u>		<u>45'</u>	<u>50'</u>	<u>5'</u>
<u>white clay</u>		<u>50'</u>	<u>75'</u>	<u>25'</u>
<u>brown clay</u>		<u>75'</u>	<u>100'</u>	<u>25'</u>
<u>caliche</u>		<u>100'</u>	<u>105'</u>	<u>5'</u>
<u>brown clay</u>		<u>105'</u>	<u>130'</u>	<u>25'</u>
<u>white clay</u>		<u>130'</u>	<u>140'</u>	<u>10'</u>

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 12 Inches To 140' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140'</u>

Perforations:
Type perforation Saw cut
Size perforation 18" x 3"
From 100 feet to 140' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet



Date started October 16, 2000
Date completed October 18, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow _____ G.P.M.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lakes Construction Co. Contractor
Address 4191 S Jackie St. Pahrump, Nevada 89048 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest Lakes By driller performing actual drilling on site or contractor
Date October 20, 2000